

## **A SCHOOL BOILER GIVES OUT.**

When Janitor Otis of the Omaha View school returned from breakfast Friday morning, about 7:30 o'clock, he noticed that the water in the glass gauge of the steam heating boiler had fallen nearly an inch. An investigation disclosed a "rip" in the boiler, and that the water was leaking into the fire box. The fire was drawn and the water turned from the boiler. No school was held, and workmen were set to work repairing the defect. It appears that the boiler is an old iron one which has been in use about eight years. Otis says there was no possible danger of an explosion, and the workmen say that there were no indications of an explosion apparent. The rip is about three feet in length and about a quarter of an inch in width. School will open again Monday morning.

### CITATION (APA STYLE)

(1895, November 23). *Omaha World-Herald*, p. 1. Available from NewsBank: America's News – Historical and Current: <https://infoweb.newsbank.com/apps/news/document-view?p=AMNEWS&docref=image/v2:1106B5BBD4B623A8@EANX-NB-132FC42A59F5E4C5@2413521-132D29CF861B7A87@0-132D29CF861B7A87@>.

© This entire service and/or content portions thereof are copyrighted by NewsBank and/or its content providers.